

## SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 744/24

Dated: 07/06/2024

It is certified that an inspection team headed by Mrs. Saitaja Aparajita Satpathy  
 (Name of Officers with designation) from Asst. Executive Engineer, RWSS Dept.  
 (Name of Department/ Office) inspected the Macaulay International School, Gyan  
 Vihar, Barang  
 (Name & Address of the school) on 07/06/2024 (date of inspection) and found that the  
Macaulay International School (Name of school) has safe drinking water  
 facilities for the students and members of staff of the institution and is maintaining the hygienic  
 sanitation condition in the school building & the campus as per norms prescribed by the Central/  
 State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal:

Saitaja  
07/06/24  
 Asst. Executive Engineer (RWSS)  
 Circle-II, Cuttack

Name

: Mrs. Saitaja Aparajita Satpathy

Designation

: Asst. Executive Engineer

Name & Address of the Office / Department : Rural  
 Water Supply and Sanitation (RWSS)  
 Circle - II  
 Cuttack

To

Principal

Macaulay International School  
Gyan Vihar, Barang, Cuttack-05  
 (Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.





Department of Health & family Welfare  
Govt. of Odisha

Ref No:- 939

Dated:- 09.05.2024

WATER TESTING REPORT

From,  
Office of the CDMO(Health Dept.)  
Address: Buxibazar, Cuttack  
Odisha-753008

To,  
The Chairman/Principal  
School Name:- Macaulay International School  
Address: At-Gyanvihar, Po-Belagachhia,Barang,Dist- Cuttack

**Sub- Water Testing Report (Collected from Drinking Water Point of Macaulay International School)**

I hereby declare that I have inspected the Macaulay International School under the Trust of Subas Foundation Building and premises located At-Gyan Vihar, Po-Belagachhia under Panchayat-Kunheipada, Block-Barang, Cuttack on the 30<sup>th</sup> of April'2024 & Certify That.

**Report of Water Tasting**

Sl. No	Parameters	Sample ID-IR	Sample ID-2F	Method of Test adopted as per standards	Requirement as per standard specification IS 10500:2012	
					Acceptable Limit	Permissible Limit
1.	pH	7.62	6.33	IS 3025(Part-11)	6.5-8.5	No Relaxation
2.	Sulphate(mg/l)	28.571	71.429	IS 3025(Part-24)	Max 200	Max 400
3.	Conductivity (us/cm)	522.9	46.21	IS 3025(Part-14)	.....	.....
4.	Chloride (mg/l)	16.995	4.998	IS 3025(Part-32)	Max 250	Max 1000
5.	Total Hardness (mg/l)	174	10	IS 3025(Part-21)	Max 200	Max 600
6.	Total Dissolved Solids (mg/l)	246.7	24.98	IS 3025(Part-16)	Max 500	Max 2000
7.	Iron(mg/l)	1.05	0.85	IS 3025(Part-53)	Max 1	No Relaxation

CDMO  
Signature of the (CDMO)  
(with office seal)  
Date: